

SOLICITATION NO. W911WN-04-R-0003

CHARLEROI LOCKS, CONTRACT 1
CHARLEROI LOCKS AND DAM
MONONGAHELA RIVER, PENNSYLVANIA

A

M

E

N

D

M

E

N

T

NUMBER 3

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0003</div>		3. EFFECTIVE DATE <div style="text-align: center;">26-MAY-2004</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">W81ET4-4058-0100</div>		5. PROJECT NO. (If applicable)	
6. ISSUED BY US ARMY ENGR DISTRICT PGH 727 WM S MOORHEAD FEDERAL BLDG 1000 LIBERTY AVENUE PITTSBURGH PA 15222-4186 Michele R. Hutfles C02 (412)395-7479		CODE W911WN		7. ADMINISTERED BY (If other than Item 6) US ARMY ENGR DISTRICT PGH 727 WM S MOORHEAD FEDERAL BLDG 1000 LIBERTY AVENUE PITTSBURGH PA 15222-4186		CODE W911WN	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP code)				(X)		9A. AMENDMENT OF SOLICITATION NO. <div style="text-align: center;">W911WN-04-R-0003</div>	
						9B. DATED (SEE ITEM 11) <div style="text-align: center;">26-APR-2004</div>	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

SEE ATTACHED

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR <div style="text-align: center;">(Signature of person authorized to sign)</div>	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY <div style="text-align: center;">(Signature of Contracting Officer)</div>	16C. DATE SIGNED

The following clarifications are made to the Request for Proposal for Charleroi Locks, Contract 1, Charleroi Locks and Dam, Monongahela Rive, Pennsylvania:

Question for Clarification:

The following is a question received by the Government and the response to the question:

Q. Is it possible for the contractor to adjust the elevation of the construction joints in the tremie concrete lifts in the non-cofferbox walls to suit means and methods of construction?

A. The first lift of tremie concrete in the non-cofferbox sections for the river wall shall encase the foundation reinforcement cage. Therefore, the height of the first tremie lift can not be reduced. The lift height for lifts in the tremie portion other than the first lift may be lowered to accommodate the contractor's methods. Note that the top of the tremie lifts must be prepared for placement of subsequent lifts and therefore there will be more preparation work involved if the lift heights are lowered and more lifts are required. In addition, note that there will be no reduction or changes granted for the placement rate (time between placement of subsequent lifts), placement temperature or other concrete placement parameters based on a reduced lift height. Changes to contract Drawings 037-LCH20/12, 20/15 and 20/25 to reflect this will be made at a later date.